

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

Attestation of Compliance

No. E8N 10 11 72433 044

Holder of Certificate: GD Midea Heating & Ventilating Equipment Co.,Ltd.

Penglai Industry Road, Beijiao, Shunde
528311 Foshan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Name of Object: Electric fan-coil units
(Fan Coil Unit)

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: 647101030201

Date, 2010-11-17 (Tony Liu)



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 5



Product Service

Attestation of Compliance
No. E8N 10 11 72433 044

Model(s):

MKH1-150, MKH2-150, MKH3-150,
 MKH1-250, MKH2-250, MKH3-250, MKH1-300,
 MKH2-300, MKH3-300, MKH1-400, MKH2-400,
 MKH3-400, MKH1-450, MKH2-450, MKH3-450,
 MKH1-500, MKH2-500, MKH3-500, MKH1-600,
 MKH2-600, MKH3-600, MKH1-800, MKH2-800,
 MKH3-800, MKH1-900, MKH2-900, MKH3-900,
 MKD-300N, MKD-300NF, MKD-400N, MKD-400NF,
 MKD-500N, MKD-500NF, MKA-750N, MKA-750NF,
 MKA-950N, MKA-950NF, MKA-1200N, MKA-1200NF,
 MKA-1500N, MKA-1500NF, MKF1-150, MKF2-150,
 MKF3-150, MKF4-150, MKF5-150, MKF1-250,
 MKF2-250, MKF3-250, MKF4-250, MKF5-250,
 MKF1-300, MKF2-300, MKF3-300, MKF4-300,
 MKF5-300, MKF1-400, MKF2-400, MKF3-400,
 MKF4-400, MKF5-400, MKF1-450, MKF2-450,
 MKF3-450, MKF4-450, MKF5-450, MKF1-500,
 MKF2-500, MKF3-500, MKF4-500, MKF5-500,
 MKF1-600, MKF2-600, MKF3-600, MKF4-600,
 MKF5-600, MKF1-800, MKF2-800, MKF3-800,
 MKF4-800, MKF5-800, MKF1-900, MKF2-900,
 MKF3-900, MKF4-900, MKF5-900

Description of Object:

Rated voltage:	220-240 V
Rated frequency:	50 Hz
Rated power input:	See attachment
Protection class:	I

Tested according to:

EN 55014-1:2006
 EN 55014-2/A2:2008
 EN 61000-3-2/A2:2009
 EN 61000-3-3:2008



Attestation of Compliance

No. E8N 10 11 72433 044

Model No	Rated Input (W)	Rated Current (A)
MKH1-150	27	0.12
MKH2-150	29	0.13
MKH3-150	29	0.13
MKH1-250	45	0.2
MKH2-250	45	0.2
MKH3-250	45	0.2
MKH1-300	40	0.19
MKH2-300	44	0.2
MKH3-300	44	0.2
MKH1-400	46	0.2
MKH2-400	47	0.2
MKH3-400	47	0.2
MKH1-450	40	0.2
MKH2-450	40	0.2
MKH3-450	40	0.2
MKH1-500	49	0.22
MKH2-500	51	0.23
MKH3-500	51	0.23
MKH1-600	77	0.3
MKH2-600	77	0.3
MKH3-600	77	0.3
MKH1-800	118	0.5
MKH2-800	118	0.5
MKH3-800	118	0.5
MKH1-900	137	0.61
MKH2-900	143	0.64
MKH3-900	143	0.64
MKD-300N	50	0.22
MKD-300NF	50	0.22
MKD-400N	70	0.30



Attestation of Compliance

No. E8N 10 11 72433 044

MKD-400NF	70	0.30
MKD-500N	87	0.4
MKD-500NF	87	0.4
MKA-750N	130	0.6
MKA-750NF	188	0.82
MKA-950N	190	0.9
MKA-950NF	190	0.9
MKA-1200N	180	0.86
MKA-1200NF	197	1.0
MKA-1500N	228	0.86
MKA-1500NF	234	1.2
MKF1-150	27	0.12
MKF2-150	29	0.13
MKF3-150	29	0.13
MKF4-150	27	0.12
MKF5-150	29	0.13
MKF1-250	29	0.14
MKF2-250	30	0.15
MKF3-250	30	0.15
MKF4-250	29	0.14
MKF5-250	30	0.15
MKF1-300	40	0.19
MKF2-300	44	0.2
MKF3-300	44	0.19
MKF4-300	40	0.19
MKF5-300	44	0.2
MKF1-400	46	0.2
MKF2-400	47	0.21
MKF3-400	44	0.19
MKF4-400	46	0.2
MKF5-400	47	0.21



Attestation of Compliance

No. E8N 10 11 72433 044

MKF1-450	39	0.2
MKF2-450	39	0.2
MKF3-450	39	0.2
MKF4-450	39	0.2
MKF5-450	39	0.2
MKF1-500	49	0.22
MKF2-500	51	0.23
MKF3-500	51	0.23
MKF4-500	49	0.22
MKF5-500	51	0.23
MKF1-600	63	0.27
MKF2-600	64	0.28
MKF3-600	64	0.28
MKF4-600	63	0.27
MKF5-600	64	0.28
MKF1-800	88	0.38
MKF2-800	97	0.42
MKF3-800	95	0.41
MKF4-800	88	0.38
MKF5-800	97	0.42
MKF1-900	137	0.61
MKF2-900	143	0.64
MKF3-900	143	0.64
MKF4-900	137	0.61
MKF5-900	137	0.61

-End-

Test report no.: 647101030201

Date, 2010-11-17

Page 5 of 5